



Computer Control Instrumentation

CCI Pty Ltd, ACN 068 036 082
ABN 43 174 948 499

91 Goodwood Rd, Goodwood
South Australia 5034
Ph: (08) 8373 6611
Fax: (08) 8373 2311
Mobile: 0419 811 558
Email: www.c-c-i.com.au
Internet: www.c-c-i.com.au
Date: Wednesday, 4 October 2006

WR150E-24

150 Watt DC/DC Converter Specification 24V@6A

Wide Range Input	60- 137 Vdc
Output Voltage	24.1Vdc (+/-100 mV)
Regulation	< 1%
Input Fuse	4A
Output Fuse	6.3A
Input LEDs are ON if I/P is	Within range 60-137Vdc
Output LEDs are ON if O/P is	> 22Vdc
Efficiency	88-92 % Depending on Load Conditions
Isolation	I/P to O/P 1kV Minimum
Isolation	I/P to GND 1kV Minimum
Isolation	O/P to GND 500V Minimum
Ripple & Noise	< 100mV (Typically <= 50mV @ 6.3A)
Operating Temperature	0-60°C